

PSYCHED FOR PSYCHROMETRICS

JULIA KEEN, P.E., PHD, ASHRAE FELLOW, HBDP

KANSAS STATE UNIVERSITY

PROFESSOR, ARCHITECTURAL ENGINEERING & CONSTRUCTION SCIENCE

KEEN DESIGNS, PA



This ASHRAE Distinguished Lecturer is brought to you by the ASHRAE Society Chapter Technology Transfer Committee

Lecturer presentations and/or opinions do not necessarily reflect the policies or position of ASHRAE or the chapter.

PLEASE!

- SILENCE PHONES
- DISTINGUISHED LECTURER EVALUATION FORMS ARE VERY IMPORTANT. PLEASE COMPLETE AT THE END OF THE PRESENTATION AND RETURN TO THE CTC OR PROGRAM CHAIR.

MORE INFORMATION ON THE DL PROGRAM AVAILABLE AT: WWW.ASHRAE.ORG/DISTINGUISHEDLECTURERS

VOLUNTEER!

www.ashrae.org/volunteer

**BECOME A FUTURE LEADER IN ASHRAE –
WRITE THE NEXT CHAPTER IN YOUR CAREER**

ASHRAE Members who are active at their chapter and society become leaders and bring information and technology back to their job.

YOU ARE NEEDED FOR:

- ❖ SOCIETY TECHNICAL COMMITTEES
- ❖ SOCIETY STANDARD COMMITTEES
- ❖ CHAPTER MEMBERSHIP PROMOTION
- ❖ CHAPTER RESEARCH PROMOTION
- ❖ CHAPTER STUDENT ACTIVITIES
- ❖ CHAPTER TECHNOLOGY TRANSFER



FIND YOUR PLACE IN ASHRAE AND VOLUNTEER

OVERVIEW

- Review of Basics
- Space Conditions
- Part Loads
- Energy Recovery
- Condensation



REVIEW OF BASICS

PSYCHOMETRICS DEFINED

THE SCIENCE THAT INVOLVES THE PROPERTIES OF MOIST AIR AND THE PROCESS IN WHICH THE TEMPERATURE AND/OR WATER VAPOR CONTENT OF THE MIXTURE ARE CHANGED

"UNDERSTANDING PSYCHROMETRICS"





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL




ELEMENTS OF PSYCH CHART

- DRY-BULB TEMPERATURE (DB)
- WET-BULB TEMPERATURE (WB)
- RELATIVE HUMIDITY (RH)
- HUMIDITY RATIO (W OR G)
- DEW-POINT TEMPERATURE (DP)
- SPECIFIC ENTHALPY (h)
- SPECIFIC VOLUME (v)


Dry Bulb °F (DB)

- Air temperature measured by an ordinary thermometer
- Easiest psychrometric property to measure




Wet Bulb °F (WB)

- Temperature of evaporation
- Measured with a wet wick in airstream



Relative Humidity % (RH)

- The ratio between the mass of water vapor present & the maximum mass of water vapor that can be contained at the same DB temperature




$$\% \text{ RH} = \frac{\text{moisture the air is holding}}{\text{moisture the air can hold}}$$

Humidity Ratio $\#_{\text{water}}/\#_{\text{air}}$ (W)

- Ratio of mass of water vapor to the mass of dry air
- Moisture content
- Also referred to as *Grains*


7000 grains = 1 # water

$1W \times 7000 = \text{Grains}$




Dew Point °F (DP)

- Surface temperature at which condensation occurs
- Surrounding air conditions relative to a surface




Enthalpy BTU/#_{air} (*h*)

- Convenient sum of the two components of the energy balance equation:
internal energy
+
flow-work energy



Specific Volume $\text{Ft}^3/\#_{\text{air}}$ (v)


- Volume per unit mass



Given two pieces of information, a point can be located and other properties for that point can be determined

**Room conditions:
75°F and 50% RH**

28.2 Btu/#_{air}



• **Vertical movement** = Change in moisture

◦ Down: Dehumidify (remove moisture)

▪ Decrease W ($\#_{\text{water}}/\#_{\text{air}}$)

◦ Up: Humidify (add moisture)

▪ Increase W ($\#_{\text{water}}/\#_{\text{air}}$)

◦ Latent

• **Horizontal movement** = Change in temp


◦ Left: Cool

▪ Decrease DB ($^{\circ}\text{F}$)

◦ Right: Heat

▪ Increase DB ($^{\circ}\text{F}$)

◦ Sensible





SPACE CONDITIONS

SPACE LOAD AND SPACE CONDITIONS

- Using a standard unit with a delivery air condition of 55°F /90%, what room conditions can be maintained for the following space:
- 40'x50' classroom:
 - Envelope = 6,500 BTUh (all sensible)
 - Equipment & Lights = 1,700 BTUh (all sensible)
 - People = ?

Table 1 Representative Rates at Which Heat and Moisture Are Given Off by Human Beings in Different States of Activity

Degree of Activity	Location	Total Heat, Btu/h		Sensible Heat, Btu/h	Latent Heat, Btu/h	% Sensible Heat that is Radiant ^b	
		Adult Male	Adjusted, M/F ^a			Low V	High V
Seated at theater	Theater	390	350	245	105	60	27
Seated, very light work	Offices, hotels, apartments	450	400	245	155		
Moderately active office work	Offices, hotels, apartments	475	450	250	200		
Standing, light work; walking	Department store; retail store	550	450	250	200	58	38
Walking, standing	Drug store, bank	550	500	250	250		
Sedentary work	Restaurant ^c	490	550	275	275		
Light bench work	Factory	800	750	275	475		
Moderate dancing	Dance hall	900	850	305	545	49	35
Walking 3 mph; light machine work	Factory	1000	1000	375	625		
Bowling ^d	Bowling alley	1500	1450	580	870		
Heavy work	Factory	1500	1450	580	870	54	19
Heavy machine work; lifting	Factory	1600	1600	635	965		
Athletics	Gymnasium	2000	1800	710	1090		

Table 6-1 Minimum Ventilation Rates in Breathing Zone

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values Occupant Density		Air Class	OS (6.2.6.1.4)
	cfm/ person	L/s- person	cfm/ft ²	L/s-m ²	#/1000 ft ² or #/100 m ²			
Animal Facilities								
Animal exam room (veterinary office)	10	5	0.12	0.6	20		2	
Animal imaging (MRI/CT/PET)	10	5	0.18	0.9	20		3	
Animal operating rooms	10	5	0.18	0.9	20		3	
Animal postoperative recovery room	10	5	0.18	0.9	20		3	
Animal preparation rooms	10	5	0.18	0.9	20		3	
Animal procedure room	10	5	0.18	0.9	20		3	
Animal surgery scrub	10	5	0.18	0.9	20		3	
Large-animal holding room	10	5	0.18	0.9	20		3	
Necropsy	10	5	0.18	0.9	20		3	
Small-animal-cage room (static cages)	10	5	0.18	0.9	20		3	
Small-animal-cage room (ventilated cages)	10	5	0.18	0.9	20		3	
Correctional Facilities								
Booking/waiting	7.5	3.8	0.06	0.3	50		2	
Cell	5	2.5	0.12	0.6	25		2	
Dayroom	5	2.5	0.06	0.3	30		1	
Guard stations	5	2.5	0.06	0.3	15		1	
Educational Facilities								
Art classroom	10	5	0.18	0.9	20		2	
Classrooms (ages 5 to 8)	10	5	0.12	0.6	25		1	
Classrooms (age 9 plus)	10	5	0.12	0.6	35		1	
Computer lab	10	5	0.12	0.6	25		1	
Daycare sickroom	10	5	0.18	0.9	25		3	
Daycare (through age 4)	10	5	0.18	0.9	25		2	
Lecture classroom	7.5	3.8	0.06	0.3	65		1	✓
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150		1	✓
Libraries	5	2.5	0.12	0.6	10			
Media center	10	5	0.12	0.6	25		1	
Multiuse assembly	7.5	3.8	0.06	0.3	100		1	✓
Music/theater/dance	10	5	0.06	0.3	35		1	✓
Science laboratories	10	5	0.18	0.9	25		2	

a. Outpatient facilities to which the rates apply are freestanding birth centers, urgent care centers, neighborhood clinics and physicians offices, Class 1 imaging facilities, outpatient psychiatric facilities, outpatient rehabilitation facilities, and outpatient dental facilities.

b. The requirements of this table provide for acceptable IAQ. The requirements of this table do not address the airborne transmission of airborne viruses, bacteria, and other infectious organisms.

Informative Note: These rates are intended only for outpatient dental clinics where the amount of nitrous oxide is limited. They are not intended for dental operatories in institutional buildings where nitrous oxide is piped.



ANSI/ASHRAE Standard 62.1-2019
(Supersedes ANSI/ASHRAE Standard 62.1-2016)
Includes ANSI/ASHRAE addenda listed in Appendix O

Ventilation for Acceptable Indoor Air Quality

See Appendix O for approval dates by ASHRAE and the American National Standards Institute.

This Standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the Standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased from the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2019 ASHRAE ISSN 1041-2336



This file is licensed to Dennis Wessel (dwessel49@gmail.com). Download Date: 12/5/2019

Table 6-1 Minimum Ventilation Rates in Breathing Zone

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values
	cfm/ person	L/s- person	cfm/ft ²	L/s-m ²	Occupant Density
					#/1000 ft ² or #/100 m ²
Educational Facilities					
Art classroom	10	5	0.18	0.9	20
Classrooms (ages 5 to 8)	10	5	0.12	0.6	25
Classrooms (age 9 plus)	10	5	0.12	0.6	35
Computer lab	10	5	0.12	0.6	25
Daycare sickroom	10	5	0.18	0.9	25
Daycare (through age 4)	10	5	0.18	0.9	25
Lecture classroom	7.5	3.8	0.06	0.3	65
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150
Libraries	5	2.5	0.12	0.6	10
Media center	10	5	0.12	0.6	25
Multiuse assembly	7.5	3.8	(40'x50') x (65 p		
Music/theater/dance	10	5	0.06	0.3	35
Science laboratories	10	5	0.18	0.9	25

$$(40' \times 50') \times (65 \text{ people}/1000\text{ft}^2) = 130 \text{ people}$$

SPACE LOAD AND SPACE CONDITIONS

- Using a standard unit with a delivery air condition of 55°F /90%, what room conditions can be maintained for the following space:
- 40'x50' classroom:
 - Envelope = 6,500 BTUh (all sensible)
 - Equipment & Lights = 1,700 BTUh (all sensible)
 - People = 245 BTUh/person x 130 people = 31,850 BTUh Sensible
155 BTUh/person x 130 people = 20,150 BTUh Latent

SPACE LOAD AND SPACE CONDITIONS

- Sensible Load: 40,050 BTUh
- Latent Load: 20,150 BTUh
- Total Load: 60,200 BTUh
- Sensible Heat Ratio: $q_s/q_T = 40,050/60,200 = 0.665$





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL








ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL







ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL







ASHRAE PSYCHROMETRIC CHART NO. 1


NORMAL TEMPERATURE


BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY


COPYRIGHT 1992 ASHRAE

SEA LEVEL









How much cfm?

$$q_s = 1.1 \text{ cfm}(\Delta T)$$

$$40,050 \text{ BTU/h} = 1.1 (\text{cfm}) (75-55)$$

$$\text{cfm} = 1820$$

REQUIRED UNIT / COIL CAPACITY

- Room load is only one element – also dependent on ventilation
- Classroom with 130 people

Table 6-1 Minimum Ventilation Rates in Breathing Zone

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values
	cfm/ person	L/s- person	cfm/ft ²	L/s-m ²	Occupant Density
					#/1000 ft ² or #/100 m ²
Educational Facilities					
Art classroom	10	5	0.18	0.9	20
Classrooms (ages 5 to 8)	10	5	0.12	0.6	25
Classrooms (age 9 plus)	10	5	0.12	0.6	35
Computer lab	10	5	0.12	0.6	25
Daycare sickroom	10	5	0.18	0.9	25
Daycare (through age 4)	10	5	0.18	0.9	25
Lecture classroom	7.5	3.8	0.06	0.3	65
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150
Libraries	5	2.5	0.12	0.6	10
Media center	10	5	0.12	0.6	25
Multiuse assembly	7.5	3.8	0.06	0.3	100
Music/theater/dance	10	5	0.06	0.3	35
Science laboratories	10	5	0.18	0.9	25

$$+ \frac{(40' \times 50') 0.06 \text{ cfm/ft}^2 + (130 \text{ people}) 7.5 \text{ cfm/person}}{1095 \text{ cfm outdoor air}}$$





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL





COIL LOAD (UNIT CAPACITY)

- $Q_T = 4.5 \text{ cfm } \Delta h$



ASHRAE PSYCHROMETRIC CHART NO. 1
NORMAL TEMPERATURE
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY
COPYRIGHT 1992 ASHRAE

SEA LEVEL





COIL LOAD (UNIT CAPACITY)

- $Q_T = 4.5 \text{ cfm } \Delta h$
= $4.5 (1820) (33.8 - 22.3)$
= $94,185 \text{ BTUh} \rightarrow 94,185 \text{ BTUh} / 12,000 = 7.8 \text{ tons}$



ASHRAE PSYCHROMETRIC CHART NO. 1
NORMAL TEMPERATURE
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY
COPYRIGHT 1992 ASHRAE

SEA LEVEL



COIL LOAD (UNIT CAPACITY)

- $Q_T = 4.5 \text{ cfm } \Delta h$
 $= 4.5 (1820) (33.8 - 22.3)$
 $= 94,185 \text{ BTUh} \rightarrow 94,185 \text{ BTUh} / 12,000 = 7.8 \text{ tons}$
- | | |
|--|--|
| $Q_s = 1.1 \text{ cfm } \Delta T$
$= 1.1 (1820) (84 - 55)$
$= 58,058 \text{ BTUh}$ | $Q_L = 4840 \text{ cfm } \Delta w$
$= 4840 (1820) (0.0124 - 0.0084)$
$= 35,235 \text{ BTUh}$ |
| <div style="text-align: center;">$Q_T = 93,293 \text{ BTUh} = 7.8 \text{ tons}$</div> | |





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL







ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL



SMALL CLASS SIZE

- 40'x50' classroom (design peak → part load) :
 - Envelope = 6,500 BTUh
 - Equipment & Lights = 1,700 BTUh
 - People = 245 BTUh/person x 130 people = 31,850 BTUh Sensible
245 BTUh/person x 30 people = 7,350 BTUh Sensible
155 BTUh/person x 130 people = 20,150 BTUh Latent
155 BTUh/person x 30 people = 4,650 BTUh Latent

SPACE LOAD AND SPACE CONDITIONS

- Sensible Load: 40,050 BTUh 15,550 BTUh
- Latent Load: 20,150 BTUh 4,650 BTUh
- Total Load: 60,200 BTUh 20,200 BTUh
- Sensible Heat Ratio: $q_s/q_T = 40,050/60,200 = 0.665$
15,550/20,200 = 0.77



ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL





Table 6-1 Minimum Ventilation Rates in Breathing Zone

Occupancy Category	People Outdoor Air Rate R_p		Area Outdoor Air Rate R_a		Default Values
	cfm/ person	L/s- person	cfm/ft ²	L/s-m ²	Occupant Density
					#/1000 ft ² or #/100 m ²
Educational Facilities					
Art classroom	10	5	0.18	0.9	20
Classrooms (ages 5 to 8)	10	5	0.12	0.6	25
Classrooms (age 9 plus)	10	5	0.12	0.6	35
Computer lab	10	5	0.12	0.6	25
Daycare sickroom	10	5	0.18	0.9	25
Daycare (through age 4)	10	5	0.18	0.9	25
Lecture classroom	7.5	3.8	0.06	0.3	65
Lecture hall (fixed seats)	7.5	3.8	0.06	0.3	150
Libraries	5	2.5	0.12	0.6	10
Media center	10	5	0.12	0.6	25
Multiuse assembly	7.5	3.8	0.06	0.3	100
Music/theater/dance	10	5	0.06	0.3	35
Science laboratories	10	5	0.18	0.9	25

$$+ \frac{(40' \times 50') 0.06 \text{ cfm/ft}^2 + (30 \text{ people}) 7.5 \text{ cfm/person}}{345 \text{ cfm outdoor air}}$$





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL



REDUCED COIL LOAD

- $Q_T = 4.5 \text{ cfm } \Delta h$
 $= 4.5 (1820) (29.7 - 22.3)$
 $= 60,606 \text{ BTUh} \rightarrow 60,606 \text{ BTUh} / 12,000 = 5.1 \text{ tons}$
 - $Q_s = 1.1 \text{ cfm } \Delta T$
 $= 1.1 (1820) (77.8 - 55)$
 $= 45,645 \text{ BTUh}$
 - $Q_L = 4840 \text{ cfm } \Delta w$
 $= 4840 (1820) (0.0102 - 0.0084)$
 $= 15,856 \text{ BTUh}$
- $Q_T = 61,500 \text{ BTUh} = 5.1 \text{ tons}$

UNIT SIZE IMPACT ON PERFORMANCE

- UNIT CAPACITY SELECTED @ PEAK = 8 TONS
- ONLY NEED 5 TONS WITH FEWER PEOPLE

This is GREAT!!!!

**We have plenty of
capacity**

UNIT SIZE IMPACT ON PERFORMANCE

- UNIT CAPACITY SELECTED @ PEAK = 8 TONS
- ONLY NEED 5 TONS WITH FEWER PEOPLE

BUT....WAIT

**What happens when you
provide 8 tons of cooling
to a space that only need
5 tons?**

UNIT SIZE IMPACT ON PERFORMANCE

- UNIT CAPACITY SELECTED @ PEAK = 8 TONS
- ONLY NEED 5 TONS WITH FEWER PEOPLE

BUT....WAIT
What happens when you
provide 8 tons of cooling
to a space that only need
5 tons?



UNIT SIZE IMPACT ON PERFORMANCE

- UNIT CAPACITY SELECTED @ PEAK = 8 TONS
- A **SIGNIFICANT** PORTION OF THE TIME THE FULL 8 TONS IS NOT NEEDED
 - LESS PEOPLE
 - LOWER OA TEMPERATURES
 - LESS SOLAR LOAD
 - NOT ALL EQUIPMENT/LIGHTS ON

UNIT SIZE IMPACT ON PERFORMANCE

- UNIT CAPACITY SELECTED @ PEAK = 8 TONS
- A **SIGNIFICANT** PORTION OF THE TIME THE FULL 8 TONS IS NOT NEEDED
 - LESS PEOPLE
 - LOWER OA TEMPERATURES
 - LESS SOLAR LOAD
 - NOT ALL EQUIPMENT/LIGHTS ON

WHAT CAN WE DO?

UNIT SIZE IMPACT ON PERFORMANCE

$$q_s = 1.1 \text{ CFM } \Delta T$$


- Peak Load: $40,050 = 1.1 \text{ CFM } (75-55) \rightarrow 1820 \text{ cfm}$
- Reduced Sensible Load: $15,550 \text{ BTUh}$ (fewer people)
- Reduced load, change ΔT or change airflow?

Option 1: Keep air flow = 1820 cfm; **Increase SA temp to 67°F**



ASHRAE PSYCHROMETRIC CHART NO. 1
NORMAL TEMPERATURE
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY
COPYRIGHT 1992 ASHRAE

SEA LEVEL



1475 cfm
RA @
75°FDB/
53%





345 cfm
OA @
90°F DB/
72°F WB



1820 cfm
MA @
77.8°FDB/
64.8°F WB

Coil Performance Line





This will control temperature
(sensible load)
BUT
INADEQUATE moisture
removal (latent load)!

UNIT SIZE IMPACT ON PERFORMANCE

$$q_s = 1.1 \text{ CFM } \Delta T$$

- Peak Load: $40,050 = 1.1 \text{ CFM } (75-55) \rightarrow 1820 \text{ cfm}$
- Reduced Sensible Load: $15,550 \text{ BTUh}$ (fewer people)
- Reduced load, change ΔT or change airflow?

Option 1: Keep air flow = 1820 cfm; **Increase SA temp to 67°F**

Option 2: Keep $\Delta T = 20^\circ\text{F}$; **Reduce airflow = 705 cfm**

Need to ensure adequate ventilation & space pressure

SOLUTIONS

- DEPENDS ON THE SYSTEM TYPE, APPLICATION, AND PRIORITIES
 - REHEAT
 - USE WHEN THE AIR VOLUME CANNOT BE ALTERED
 - BEST IF WASTE HEAT IS USED
 - POTENTIAL FOR INCREASED FAN & REHEAT ENERGY




ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL



1475 cfm
RA @
75°FDB/
53%



345 cfm
OA @
90°F DB/
72°F WB



1820 cfm
MA @
77.8°FDB/
65.2°F WB

Coil Performance Line

55°F/90%

Reheat

75°F/53%


90°F/72°F

67°F



ASHRAE PSYCHROMETRIC CHART NO. 1
NORMAL TEMPERATURE
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY
COPYRIGHT 1992 ASHRAE

SEA LEVEL



1475 cfm
RA @
75°FDB/
53%




345 cfm
OA @
90°F DB/
72°F WB




1820 cfm
MA @
77.8°FDB/
65.2°F WB

Coil Performance Line



SOLUTIONS

- DEPENDS ON THE SYSTEM TYPE, APPLICATION, AND PRIORITIES
 - REHEAT
 - FACE AND BYPASS COILS
 - CONFIRM UNIT ABILITY
 - MAINTAIN AIRFLOW VOLUME






ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE

BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992 ASHRAE

SEA LEVEL



1475 cfm
RA @
75°FDB/
53%




345 cfm
OA @
90°F DB/
72°F WB



1820 cfm
MA @
77.8°FDB/
65.2°F WB

Mixing of Airstreams



SOLUTIONS


- DEPENDS ON THE SYSTEM TYPE, APPLICATION, AND PRIORITIES
 - REHEAT
 - FACE AND BYPASS COILS
 - MULTIPLE UNITS OR STAGED/MODULATING COMPRESSORS





ENERGY RECOVERY


Why use energy recovery?

- Reduce OA load
- W/out energy recovery the coil load is 7.8 tons
- 1095 cfm OA
- 1820 cfm SA
- 60% OA






Assuming an effectiveness of 50%
(sensible and latent same performance)



Pre-conditioned OA
82.5°F





6.2 tons vs 7.8 tons = 20% savings in capacity



CONDENSATION

Will condensation
form on a SA duct
carrying 55°F if routed
in the conditioned
space w/out
insulation?





The ambient temperature sets the dew point.
Dew point at 75°F/58% RH = 59°F
 $55^{\circ}\text{F} < 59^{\circ}\text{F} \rightarrow$ condensation will form



QUESTIONS

JULIA KEEN

jkeen@ksu.edu